Dufferin-Peel Catholic District School Board
Regulated Water Testing Summary for Schools 2023

School Name	DWIS Number	Municipal Address	Testing Dates	Testing Times	Sample ID	Sample Location Description	Results: Standing (mg/L)	Results: Flushed (mg/L)
Ascension of Our Lord	500019319	7640 Anaka Drive, Mississauga	19-Aug-23	8:12 am - 8:47 am	DF-01	Outside CR. 105	0.00061	0.00024
			19-Aug-23	8:20 am - 8:55 am	CAF		0.00304	0.00064
			19-Aug-23	8:27 am - 9:02 am	DF-02	Outside Mechanical Room	0.00001	0.00001
			19-Aug-23	8:33 am - 9:08 am	DF-03	Outside CR. 309	0.00018	0.00016
Bishop Francis Allen	500000469	325 McMurchy Avenue South, Brampton	12-Aug-23	8:57 am - 9:47 am	KG-1		0.00401	0.00163
			12-Aug-23	9:01 am - 9:46 am	DF-01	Outside Staff Room	0.00050	0.00035
			12-Aug-23	9:05 am - 9:40 am	DF-02	Outside CR. 8	0.00100	0.00056
Cardinal Ambrozic	500198342	10 Castle Oaks Crossing, Brampton	15-Jul-23	8:38 am - 9:13 am	Caf Sink		0.00070	0.00051
			15-Jul-23	8:45 am - 9:20 am	DF 1st Floor	Outside Cosmo Room 128	0.00061	0.00031
			15-Jul-23	8:52 am - 9:47 am	DF 2nd Floor	Outside HPR 2-A	0.00012	0.00007
Cardinal Leger	500012676	75 Mary Street, Brampton	29-Jul-23	12:08 pm - 12:43 pm	Caf		0.00211	0.00070
			29-Jul-23	12:15 pm - 12:50 pm	DF-01	Outside Girls Change Room	0.00040	0.00031
			29-Jul-23	12:22 pm - 12:57 pm	DF-02	Outside Mechanical Room	0.00574	0.00175
Cardinal Newman	500012247	698 Balmoral Drive, Brampton	29-Jul-23	2:16 pm - 2:51 pm	KG-28		0.00185	0.00183
			29-Jul-23	2:23 pm - 2:58 pm	DF-01	Outside Boys Change Room	0.00172	0.00140
Father Clair Tipping	500012546	25 Mountain Berry Drive, Brampton	22-Jul-23	7:47 am - 8:27 am	KG101		0.01710	0.00379
			22-Jul-23	7:46 am - 8:26 am	DF 01	Across from KG Room 103	0.01980	0.00911
			22-Jul-23	7:50 am - 8:25 am	DF 02	Outside CR. 213	0.00002	0.00002
Father CW Sullivan	500012533	62 Seaborn Road, Brampton	29-Jul-23	12:06 pm - 12:41 pm	DF-01	Outside CR. 115	0.00006	0.00008
			29-Jul-23	12:19 pm - 12:54 pm	DF-02	Outside CR. 208	0.00001	0.00006
			29-Jul-23	12:13 pm - 12:48 pm	KG-104		0.00048	0.00502
Father Francis McSpiritt	500124645	55 Lexington Road, Brampton	15-Jul-23	12:34 pm - 1:09 pm	KG103		0.00026	0.00022
			15-Jul-23	12:39 pm - 1:14 pm	DF - 1st Floor	Outside Seminar & Across from Bathrooms	0.00001	0.00002
			15-Jul-23	12:44 pm - 1:19 pm	DF - 2nd Floor	Across from Mechanical Room	0.00011	0.00017
Fun School	500073776	44 Port Street, Mississauga	19-Aug-23	1:34 pm - 2:09 pm	CCC - Kitchen	Daycare	0.0004	0.00139
Georges Vanier	500012169	28 Finchgate Boulevard, Brampton	19-Aug-23	9:27 am - 10:02 am	KG-101		0.00331	0.00268
			19-Aug-23	9:32 am - 10:07 am	DF-01	Outside KG 102	0.00007	0.00014
			19-Aug-23	9:38 am - 10:13 am	DF-02	Boys Washroom	0.00002	0.00022
Good Shepherd	500012273	28 Red River Drive, Brampton	22-Jul-23	8:40 am - 9:20 am	KG101		0.00244	0.00200
			22-Jul-23	8:42 am - 9:19 am	DF 01	Across from KG 104	0.00136	0.00147
			22-Jul-23	8:43 am - 9:18 am	DF 02	Outside Boys Bathroom	0.00002	0.00003
Guardian Angels	500012286	62 Heatherdale Drive, Brampton	29-Jul-23	12:09 pm - 12:52 pm	KG102	Tall Sink	0.00490	0.00062
			29-Jul-23	12:10 pm - 12:53 pm	DF1	Outside Custodian Storage Room	0.00133	0.00030
			29-Jul-23	12:11 pm - 12:46 pm	DF2	Outside Custodian Storage Room	0.00138	0.00040
Holy Cross	500018994	3615 Morningstar Drive, Mississauga	15-Jul-23	3:26 pm - 4:01 pm	KG104		0.00169	0.00085
			15-Jul-23	3:31 pm - 4:06 pm	DF-01	Outside Custodian Office	0.00035	0.00033
			15-Jul-23	3:36 pm - 4:11 pm	DF-02	Outside CR. 203	0.00051	0.00036
Holy Family	500012728	61 Allan Drive, Bolton	12-Aug-23	9:47 am - 10:22 am	KG101		0.00840	0.00138
			12-Aug-23	9:54 am - 10:29 am	DF-01	Across from CR. 106	0.00001	0.00003
			12-Aug-23	10:01 am - 10:36 am	DF-02	Across from CR. 207	0.00122	0.00132
Holy Spirit	500012104	25 Bloomsbury Avenue, Brampton	15-Jul-23	10:41 am - 11:16 am	KG101		0.00039	0.00036
			15-Jul-23	10:46 am - 11:21 am	DF 1st Floor (KG102)			

Dufferin-Peel Catholic District School Board
Regulated Water Testing Summary for Schools 2023

School Name	DWIS Number	Municipal Address	Testing Dates	Testing Times	Sample ID	Sample Location Description	Results: Standing (mg/L)	Results: Flushed (mg/L)

Dufferin-Peel Catholic District School Board
Regulated Water Testing Summary for Schools 2023

School Name	DWIS Number	Municipal Address	Testing Dates	Testing Times	Sample ID	Sample Location Description	Results: Standing (mg/L)	Results: Flushed (mg/L)
St. Marguerite Bourgeoys	500012351	550 North Park Drive, Brampton	19-Aug-23	09:39 am - 10:21 am	KG101		0.00651	0.00285
			19-Aug-23	09:37 am - 10:22 am	DF-01	Outside Academic Storage	0.00008	0.00007
			19-Aug-23	09:40 am - 10:15 am	DF-02	Outside Custodian Office	0.00003	0.00004
St. Marguerite d'Youville SS	500012624	10815 Dixie Road, Brampton	22-Jul-23	10:34 am - 11:26 am	CAF01	Sink	0.00452	0.00173
			22-Jul-23	10:36 am - 11:25 am	DF01	Across from Construction Technology CR. 123	0.00115	0.00084
			22-Jul-23	10:39 am - 11:20 am	DF02	Across from CR. 205	0.00070	0.00074
			22-Jul-23	10:40 am - 11:15 am	DF03	Across from CR. 305	0.00050	0.00063
St. Maria Goretti	500012364	121 Royal Orchard Drive, Brampton	29-Jul-23	9:57 am - 10:44 am	DF1	Across from CR. 109	0.00088	0.00054
			29-Jul-23	10:00 am - 10:35 am	DF2	Outside CR. 201	0.00001	0.00001
			29-Jul-23	9:52 am - 10:42 am	KG103	Tall Sink	0.00317	0.00220
			29-Jul-23	9:55 am - 10:43 am	CCC - Kitchen	Large Sink in Daycare	0.00086	0.00064
St. Mary BR	500012689	66 Main Street South, Brampton	29-Jul-23	2:13 pm - 2:48 pm	KG-103	Kindergarten-103	0.00174	0.00070
			29-Jul-23	2:18 pm - 2:53 pm	DF-01	Across Girls Washroom	0.00037	0.00029
			29-Jul-23	2:24 pm - 2:59 pm	DF-02	Outside Library	0.00852	0.00395
St. Michael SS	500218154	9130 Columbia Way, Bolton	19-Aug-23	1:51 pm - 2:39 pm	CAF Sink		0.00268	0.00044
			19-Aug-23	1:53 pm - 2:38 pm	DF01	Across from Boys Change Room	0.00027	0.00008
			19-Aug-23	1:57 pm - 2:32 pm	DF02	Across from Computer Lab 201	0.00046	0.00022
St. Monica	500012377	60 Sterrit Drive, Brampton	29-Jul-23	3:37 pm - 4:12 pm	KG-101	Kindergarten 101	0.00210	0.00090
			29-Jul-23	3:44 pm - 4:19 pm	DF-01	Across CR. 109	0.00001	0.00003
			29-Jul-23	3:51 pm - 4:26 pm	DF-02	Outside CR. 203	0.00140	0.00078
St. Nicholas	500012741	120 Harvest Moon Drive, Bolton	12-Aug-23	1:14 pm - 1:49 pm	KG101		0.00045	0.00019
			12-Aug-23	1:21 pm - 1:56 pm	DF-01	Across from CR. 102	0.00052	0.00019
			12-Aug-23	1:30 pm - 2:05 pm	DF-02	Across from CR. 207	0.00035	0.00021
St. Patrick	500012572	11873 The Gore Road, Brampton	15-Jul-23	11:40 am - 12:15 pm	KG112		0.00306	0.00280
			15-Jul-23	11:46 am - 12:21 pm	DF 1st Floor	Across from CR. 102	0.00056	0.00052
St. Peter	500076415	46 Dawson Road, Orangeville	12-Aug-23	9:22 am - 9:57 am	KG-102	Kindergarten 102	0.00202	0.00129
			12-Aug-23	9:36 am - 10:11 am	DF-1	Outside of Classroom 115	0.00048	0.00060
St. Peter CCC			12-Aug-23	9:29 am - 10:04 am	CCC 1	Daycare	0.00188	0.00030
St. Raphael	500019202	3470 Clara Drive, Mississauga	15-Jul-23	5:33 pm - 6:06 pm	DF-01	Outside of General Office	0.00367	0.00158
			15-Jul-23	5:39 pm - 6:14 pm	DF-02	Outside of CR. 210	0.00317	0.00269
			15-Jul-23	5:45 pm - 6:20 pm	KG-105		0.00134	0.00145
St. Raphael CCC	500267814		15-Jul-23	5:50 pm - 6:25 pm	CCC - Kitchen		0.00013	9:ao

15-Jul- -DF5:45 pm - 6:20 pm 0.00145